



Chaney Lifts Ltd

11b Churchfield Road, Chalfont St. Peter, Buckinghamshire SL9 9EN
Telephone: 01753 899032 Fax: 01753 890009 Email: sales@chaneylifts.co.uk

MAINTENANCE/BREAKDOWN/REPAIR

PLEASE PRINT

Contract No. QA 649	Unit No.	Job No.	Date 2/5/19	Route	Breakdown ✓	Maintenance	Repair	Job Completed
------------------------	----------	---------	----------------	-------	----------------	-------------	--------	---------------

Site Address MOOR PARK HOUSE THE WAVED GARDEN FRESHAM.	Special Instructions
---	----------------------

Maintenance/Breakdown/Repair Details
CAUSED TO WAVED GARDEN (LIFT FOR FLAT 7)
LANDING DOOR ON GROUND FLOOR WERE GETTING STUCK ON THE THRESHOLD WARENT AND
LIFTERS MOST PROBLEM DUE TO THE WEIGHT OF THE ELECTRIC WAREWARE WITH
Repair required: YES ☒ NO ☐ THE RESIDENT HAS TO USE. RAISED SLOW DOOR TO ALLOW CLOSURE
Recommendations OF SLOW DOOR, THRESHOLD WILL HAVE TO BE SCREWED DOWN OR REPLACED.
NO UNABLE TO OPEN GROUND FLOOR DOORS WITH EURO KEY.

Client		Employee	Materials Fitted (Description)				3rd Party Spares	Client Spares	Own Spares
Name		Engineer Jim							
Position		Assistant							
Signature		Supervisor							

Travel to	Commenced	Finished	Travel From	Break	Purchases	Parking	Phone	Vehicle	Fares	Others	Mileage/Notes
114	21/01/15	31/01/18	01/18	01/18							

Supervisor's Comments	Chargeable	Non-chargeable